EXPEDITED AVAILABILITY

S P E C I F I C A T I O N S

OPTICAL HOUSING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling fins. The Optical Panel mounting surface is milled flat (surface variance <± .003") to facilitate thermal transfer of heat to housing and cooling fins. Solid barrier wall separates optical and electrical compartments. The optical and electrical compartments are integrated to create one assembly. Minimum wall thickness is .188".

ELECTRICAL HOUSING w/ INTEGRATED ARM

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling ribs surrounding the electrical compartment and a flat surface on the top of the arm to accommodate a photocell receptacle. Solid barrier wall separates optical and electrical compartments. The optical compartment and electrical compartment with the integrated support arm combine to create one assembly. Minimum wall thickness is .188". Cast and hinged driver assembly cover is integrated with wiring compartment cover.

PLED[™] OPTICS

Emitters (LED's) are arrayed on a metal core PCB panel with each emitter located on a copper thermal transfer pad and enclosed by an LED refractor. LED optics completely seal each individual emitter to meet an IP66 rating. In asymmetric distributions, a micro-reflector inside the refractor re-directs the house side emitter output towards the street side and functions as a house side shielding element. Refractors are injection molded H12 acrylic. Each LED refractor is sealed to the PCB over an emitter and all refractors are retained by an aluminum frame. Any one Panel, or group of Panels in a luminaire, have the same optical pattern. LED refractors produce standard site/area distributions. Panels are field replaceable and field rotatable in 90° increments. LED's are 3000K or 4000K CCT.

LED DRIVER(S)

Constant current electronic with a power factor of >.90 and a minimum operating temperature of -40°F/-40°C. Driver(s) is/are UL and cUL recognized and mounted directly against the Electrical Housing to facilitate thermal transfer, held down by universal clamps to facilitate easy removal. In-line terminal blocks facilitate wiring between the driver and optical arrays. Drivers accept an input of 120-277V, 50/60Hz or 347V-480V, 50,60Hz. (0 - 10V dimmable driver is standard. Driver has a minimum of 3KV internal surge protection. Luminaire supplied with 20KV surge protector for field accessible installation.)

FINISH

Electrostatically applied TGIC Polyester Powder Coat on substrate prepared with 20 PSI power wash at 140°F. Four step media blast and iron phosphate pretreatment for protection and paint adhesion. 400°F bake for maximum hardness and durability. PROJECT NAME:

PROJECT TYPE:



QSR-LED


(VL)us

PATENT PENDING

2021006

LIGHTING

U.S. ARCHITECTURAL






660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

QSR - PLED

PROMOTION



79

79

160

160

10349

10270

18240

18040

U.S. Architectural Lighting

QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ

QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ

QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ

QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ

(CX) = WW (3000K) or NW (4000K)

NOTE:

(X) = indicate voltage

660 West Avenue O. Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

48

48

48

48



LIGHTING

250W

250W

400W

400W

FIXTURE

S

HOUSING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling fins. The Optical Panel mounting surface is milled flat (surface variance $<\pm$.003") to facilitate thermal transfer of heat to housing and cooling fins. Solid barrier wall separates optical and electrical compartments. The optical and electrical compartments are integrated to create one assembly. Minimum wall thickness is .188".

CATI

 \bigcirc

Ν

S

ARM MOUNTING

F

C

F

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling ribs surrounding the electrical compartment and a flat surface on the top of the arm to accommodate a photocell receptacle. Solid barrier wall separates optical and electrical compartments. The optical compartment and electrical compartment with the integrated support arm combine to create one assembly. Minimum wall thickness is .188". Cast and hinged driver assembly cover is integrated with wiring compartment cover.

PLED[™] OPTICS

Emitters (LED's) are arrayed on a metal core PCB panel with each emitter located on a copper thermal transfer pad and enclosed by an LED refractor. LED optics completely seal each individual emitter to meet an IP66 rating. A micro-reflector inside the refractor re-directs the house side emitter output towards the street side and functions as a house side shielding element. Refractors are injection molded H12 acrylic. Each LED refractor is sealed to the PCB over an emitter and all refractors are retained by an aluminum frame. Any one Panel, or group of Panels in a luminaire, have the same optical pattern. LED refractors produce Type III and Type IV site/area distributions. Panels are field replaceable and field rotatable in 90° increments. LED's are 3000K or 4000K CCT.

LED DRIVERS

Constant current electronic with a power factor of >.90 and a minimum operating temperature of -40°F. Driver(s) is/are UL and cUL recognized and mounted directly against the Electrical Housing to facilitate thermal transfer, held down by universal clamps to facilitate easy removal. In-line terminal blocks facilitate wiring between the driver and optical arrays. Drivers accept an input of 120-277V, 50/60Hz or 347V-480V, 50,60Hz. (0 - 10V dimmable driver is standard. Driver has a minimum of 3KV internal surge protection. Luminaire supplied with 20KV surge protector for field accessible installation.)

POLE

SHAFT

4" square, fabricated from high grade structural steel tube. Shaft conforms to ASTM-A-501 - 68 specifications. Meets or exceeds minimum yield strength of 46,000 p.s.i. Wall thickness 11 Ga. (.120 wall). Reinforced hand hole is furnished with cover, shaft is furnished with ground lug located inside pole on wall opposite hand hole.

BASE PLATE

Fabricated from structural quality hot rolled steel. Meets or exceeds minimum yield strength of 36,000 p.s.i. base telescopes and is circumferentially welded to pole shaft. Slotted bolt holes provide 1 " flexibility on either side of bolt circle centerline.

ANCHORAGE

(4) anchor bolts fabricated from hot rolled steel bar, minimum yield strength of 50,000 p.s.i. bolts have "L" bend on one end and are threaded on the other end. Bolts are fully galvanized and are furnished with two nuts and two washers.

BASE COVER

Fabricated from heavy gauge quality carbon steel. Two piece cover conceals base.

FINISH (Applies to Luminaire and Pole)

Electrostatically applied TGIC Polyester Powder Coat on substrate prepared with 20 PSI power wash at 140°F. Four step sand blast and iron phosphate pretreatment for protection and paint adhesion. 400°F bake for maximum hardness and durability. Smooth finish is standard.

U.S. Architectural Lighting


660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

PROJECT NAME:

FIXTURE TYPE:




PATENT PENDING



c(Mr)us 2020174 **U.S. ARCHITECTURAL** LIGHTING

QSR - PLED

100 MPH PROMOTION



SPEC	/ O R D E R I N G	IN	FΟ	R M	A T	ΙΟ	Ν	
POLE	CATALOG #	VOLTAGE	WATTS	LUMENS	REPLACES HID	LED COUNT	OPTIONS	
15'0"- 4" Sq - 11Ga 15'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga	SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-11/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-11/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ	* = Specify Voltage 120 208 240 277	68 68 79 79 160 160	7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	HOUSE SIDE SHIELD HS-PLED SURGE PROTECTOR SP (Now included with luminaire for field installation)	
15'0"- 4" Sq - 11Ga 15'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga	SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-11/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-11/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ NOTE: (X) = indicate voltage (CX) = WW (3000K) or NW (4000K)	* = Specify Voltage	68 68 79 79 160 160	7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48		
660 West Avenue O, Palmdale, CA 93551 U.S. Architectural Lighting Phone (661) 233-2000 Fax (661) 233-2001								

U.S. Architectural Lighting

660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

Y

LIGHTING

FIXTURE

HOUSING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling fins. The Optical Panel mounting surface is milled flat (surface variance $<\pm$.003") to facilitate thermal transfer of heat to housing and cooling fins. Solid barrier wall separates optical and electrical compartments. The optical and electrical compartments are integrated to create one assembly. Minimum wall thickness is .188".

ARM MOUNTING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling ribs surrounding the electrical compartment and a flat surface on the top of the arm to accommodate a photocell receptacle. Solid barrier wall separates optical and electrical compartments. The optical compartment and electrical compartment with the integrated support arm combine to create one assembly. Minimum wall thickness is .188". Cast and hinged driver assembly cover is integrated with wiring compartment cover.

PLED[™] OPTICS

Emitters (LED's) are arrayed on a metal core PCB panel with each emitter located on a copper thermal transfer pad and enclosed by an LED refractor. LED optics completely seal each individual emitter to meet an IP66 rating. A micro-reflector inside the refractor re-directs the house side emitter output towards the street side and functions as a house side shielding element. Refractors are injection molded H12 acrylic. Each LED refractor is sealed to the PCB over an emitter and all refractors are retained by an aluminum frame. Any one Panel, or group of Panels in a luminaire, have the same optical pattern. LED refractors produce Type III and Type IV site/area distributions. Panels are field replaceable and field rotatable in 90° increments. LED's are 3000K or 4000K CCT.

LED DRIVERS

Constant current electronic with a power factor of >.90 and a minimum operating temperature of -40°F. Driver(s) is/are UL and cUL recognized and mounted directly against the Electrical Housing to facilitate thermal transfer, held down by universal clamps to facilitate easy removal. In-line terminal blocks facilitate wiring between the driver and optical arrays. Drivers accept an input of 120-277V, 50/60Hz or 347V-480V, 50, 60Hz. (0 - 10V dimmable driver is standard. Driver has a minimum of 3KV internal surge protection. Luminaire supplied with 20KV surge protector for field accessible installation.)

POLE

SHAFT

4" square, fabricated from high grade structural steel tube. Shaft conforms to ASTM-A-501 - 68 specifications. Meets or exceeds minimum yield strength of 46,000 p.s.i. Wall thickness 11 Ga. (.120 wall). Reinforced hand hole is furnished with cover, shaft is furnished with ground lug located inside pole on wall opposite hand hole.

BASE PLATE

Fabricated from structural quality hot rolled steel. Meets or exceeds minimum yield strength of 36,000 p.s.i. base telescopes and is circumferentially welded to pole shaft. Slotted bolt holes provide 1 " flexibility on either side of bolt circle centerline.

ANCHORAGE

(4) anchor bolts fabricated from hot rolled steel bar, minimum yield strength of 50,000 p.s.i. bolts have "L" bend on one end and are threaded on the other end. Bolts are fully galvanized and are furnished with two nuts and two washers.

BASE COVER

Fabricated from heavy gauge quality carbon steel. Two piece cover conceals base.

FINISH (Applies to Luminaire and Pole)

Electrostatically applied TGIC Polyester Powder Coat on substrate prepared with 20 PSI power wash at 140°F. Four step sand blast and iron phosphate pretreatment for protection and paint adhesion. 400°F bake for maximum hardness and durability. Smooth finish is standard.

U.S. Architectural Lighting


660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

PROJECT NAME:

FIXTURE TYPE:




PATENT PENDING





QSR - PLED TWIN ASSEMBLY

100 MPH PROMOTION



POLE	CATALOG #	VOLTAGE	WATTS	LUMENS	REPLACES HID	LED COUNT	OPTIONS
15'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga	SNTS-154-11-2180/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11-2180/QSR/2480/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-204-11-2180/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-II/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ	* = Specify Voltage 120 208 240 277	68 68 79 79 160 160	Lumens Per Fixture 7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	HOUSE SIDE SHIELD HS-PLED SURGE PROTECTOR
15'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 11Ga 25'0"- 4" Sq - 11Ga	SNTS-154-11-2180/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11-2180/QSR/2480/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-204-11-2180/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-11-2180/QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-11-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ	* = Specify Voltage 347 480	68 68 79 79 160 160	7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	

U.S. Architectural Lighting

660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

LIGHTING

EXPEDITED AVAILABILITY Q S R - P L E D w/ POLE RATED* FOR 140MPH (*AASHTO 2000) S P E C L F L C A T L O N S

FIXTURE

HOUSING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling fins. The Optical Panel mounting surface is milled flat (surface variance < \pm .003") to facilitate thermal transfer of heat to housing and cooling fins. Solid barrier wall separates optical and electrical compartments. The optical and electrical compartments are integrated to create one assembly. Minimum wall thickness is .188".

ARM MOUNTING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling ribs surrounding the electrical compartment and a flat surface on the top of the arm to accommodate a photocell receptacle. Solid barrier wall separates optical and electrical compartments. The optical compartment and electrical compartment with the integrated support arm combine to create one assembly. Minimum wall thickness is .188". Cast and hinged driver assembly cover is integrated with wiring compartment cover.

PLED[™] OPTICS

Emitters (LED's) are arrayed on a metal core PCB panel with each emitter located on a copper thermal transfer pad and enclosed by an LED refractor. LED optics completely seal each individual emitter to meet an IP66 rating. A micro-reflector inside the refractor re-directs the house side emitter output towards the street side and functions as a house side shielding element. Refractors are injection molded H12 acrylic. Each LED refractor is sealed to the PCB over an emitter and all refractors are retained by an aluminum frame. Any one Panel, or group of Panels in a luminaire, have the same optical pattern. LED refractors produce Type III and Type IV site/area distributions. Panels are field replaceable and field rotatable in 90° increments. LED's are 3000K or 4000K CCT.

LED DRIVERS

Constant current electronic with a power factor of >.90 and a minimum operating temperature of -40°F. Driver(s) is/are UL and cUL recognized and mounted directly against the Electrical Housing to facilitate thermal transfer, held down by universal clamps to facilitate easy removal. In-line terminal blocks facilitate wiring between the driver and optical arrays. Drivers accept an input of 120-277V, 50/60Hz or 347V-480V, 50,60Hz. (0 - 10V dimmable driver is standard. Driver has a minimum of 3KV internal surge protection. Luminaire supplied with 20KV surge protector for field accessible installation.)

POLE

SHAFT

4" square, fabricated from high grade structural steel tube. Shaft conforms to ASTM-A-501 - 68 specifications. Meets or exceeds minimum yield strength of 46,000 p.s.i. Wall thickness for 15'0" is 11Ga. (.120"). Wall thickness for 20'0" and 25'0" is 7Ga. (.180"). Reinforced hand hole is furnished with cover, shaft is furnished with ground lug located inside pole on wall opposite hand hole.

BASE PLATE

Fabricated from structural quality hot rolled steel. Meets or exceeds minimum yield strength of 36,000 p.s.i. base telescopes and is circumferentially welded to pole shaft. Slotted bolt holes provide 1 " flexibility on either side of bolt circle centerline.

ANCHORAGE

(4) anchor bolts fabricated from hot rolled steel bar, minimum yield strength of 50,000 p.s.i. bolts have "L" bend on one end and are threaded on the other end. Bolts are fully galvanized and are furnished with two nuts and two washers.

BASE COVER

Fabricated from heavy gauge quality carbon steel. Two piece cover conceals base.

FINISH (Applies to Luminaire and Pole)

Electrostatically applied TGIC Polyester Powder Coat on substrate prepared with 20 PSI power wash at 140°F. Four step sand blast and iron phosphate pretreatment for protection and paint adhesion. 400°F bake for maximum hardness and durability. Smooth finish is standard.


U.S. Architectural Lighting

660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaitg.com PROJECT NAME:

FIXTURE TYPE:







FRONT VIEW


c(UL)us

SIDE VIEW



QSR - PLED

140 MPH PROMOTION



POLE CATALOG #	VOLTAGE					
	VOLINOL	WATTS	LUMENS	REPLACES HID	LED COUNT	OPTIONS
15'0"- 4" Sq - 11Ga SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ 15'0"- 4" Sq - 11Ga SNTS-154-11/QSR/2480/PLED-IV/(X)/(CX)/RAL-8019/DBZ 20'0"- 4" Sq - 7Ga SNTS-204-7/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ 20'0"- 4" Sq - 7Ga SNTS-204-7/QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-204-7/QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ	* = Specify Voltage 120 208 240 277	68 68 79 79 160 160	7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	HOUSE SIDE SHIELD HS-PLED SURGE PROTECTOR SP (Now included with luminaire for field installation)
15'0"- 4" Sq - 11Ga SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ 15'0"- 4" Sq - 11Ga SNTS-154-11/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ 20'0"- 4" Sq - 7Ga SNTS-204-7/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ 20'0"- 4" Sq - 7Ga SNTS-204-7/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ 25'0"- 4" Sq - 7Ga SNTS-254-7/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ NOTE: (X) = indicate voltage (CX) = WW (3000K) or NW (4000K)	* = Specify Voltage	68 68 79 79 160 160	7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	

U.S. Architectural Lighting

660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com

Y

LIGHTING

S P E C I F I C A T I O N S

FIXTURE

HOUSING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling fins. The Optical Panel mounting surface is milled flat (surface variance < \pm .003") to facilitate thermal transfer of heat to housing and cooling fins. Solid barrier wall separates optical and electrical compartments. The optical and electrical compartments are integrated to create one assembly. Minimum wall thickness is .188".

ARM MOUNTING

Heavy cast low copper aluminum (A356 alloy; <0.2% copper) assembly with integral cooling ribs surrounding the electrical compartment and a flat surface on the top of the arm to accommodate a photocell receptacle. Solid barrier wall separates optical and electrical compartments. The optical compartment and electrical compartments is .18e". Cast and hinged driver assembly cover is integrated with wiring compartment cover.

PLED[™] OPTICS

Emitters (LED's) are arrayed on a metal core PCB panel with each emitter located on a copper thermal transfer pad and enclosed by an LED refractor. LED optics completely seal each individual emitter to meet an IP66 rating. A micro-reflector inside the refractor re-directs the house side emitter output towards the street side and functions as a house side shielding element. Refractors are injection molded H12 acrylic. Each LED refractor is sealed to the PCB over an emitter and all refractors are retained by an aluminum frame. Any one Panel, or group of Panels in a luminaire, have the same optical pattern. LED refractors produce Type III and Type IV site/area distributions. Panels are field replaceable and field rotatable in 90° increments. LED's are 3000K or 4000K CCT.

LED DRIVERS

Constant current electronic with a power factor of >.90 and a minimum operating temperature of -40°F. Driver(s) is/are UL and cUL recognized and mounted directly against the Electrical Housing to facilitate thermal transfer, held down by universal clamps to facilitate easy removal. In-line terminal blocks facilitate wiring between the driver and optical arrays. Drivers accept an input of 120-277V, 50/60Hz or 347V-480V, 50, 60Hz. (0 - 10V dimmable driver is standard. Driver has a minimum of 3KV internal surge protection. Luminaire supplied with 20KV surge protector for field accessible installation.)

POLE

SHAFT

4" square, fabricated from high grade structural steel tube. Shaft conforms to ASTM-A-501 - 68 specifications. Meets or exceeds minimum yield strength of 46,000 p.s.i. Wall thickness for 15'0" is 11Ga. (.120"). Wall thickness for 20'0" and 25'0" is 7Ga. (.180"). Reinforced hand hole is furnished with cover, shaft is furnished with ground lug located inside pole on wall opposite hand hole.

BASE PLATE

Fabricated from structural quality hot rolled steel. Meets or exceeds minimum yield strength of 36,000 p.s.i. base telescopes and is circumferentially welded to pole shaft. Slotted bolt holes provide 1 " flexibility on either side of bolt circle centerline.

ANCHORAGE

(4) anchor bolts fabricated from hot rolled steel bar, minimum yield strength of 50,000 p.s.i. bolts have "L" bend on one end and are threaded on the other end. Bolts are fully galvanized and are furnished with two nuts and two washers.

BASE COVER

Fabricated from heavy gauge quality carbon steel. Two piece cover conceals base.

FINISH (Applies to Luminaire and Pole)

Electrostatically applied TGIC Polyester Powder Coat on substrate prepared with 20 PSI power wash at 140°F. Four step sand blast and iron phosphate pretreatment for protection and paint adhesion. 400°F bake for maximum hardness and durability. Smooth finish is standard.


U.S. Architectural Lighting

660 West Avenue O, Palmdale, CA 93551 Phone (661) 233-2000 Fax (661) 233-2001 www.usaltg.com PROJECT NAME:

FIXTURE TYPE:




PATENT PENDING





QSR - PLED TWIN ASSEMBLY 140 MPH PROMOTION S P E C I F I C A T I O N S POLE PLED" MODULES



S P E C	/ O R D E R I N G	ΙN	FΟ	RM	ΑΤ	ΙΟ	Ν
POLE	CATALOG #	VOLTAGE	WATTS	LUMENS	REPLACES HID	LED COUNT	OPTIONS
15'0"- 4" Sq - 11Ga 15'0"- 4" Sq - 11Ga 20'0"- 4" Sq - 7Ga 20'0"- 4" Sq - 7Ga 25'0"- 4" Sq - 7Ga 25'0"- 4" Sq - 7Ga	 SNTS-154-11-2180/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11-2180/QSR/2480/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-204-7-2180/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-7-2180/QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ 	* = Specify Voltage 120 208 240 277	<u>68</u> 68 79 79 160 160	Lumens Per Fixture 7548 7480 10349 10270 18240 18040	150W 150W 250W 250W 400W 400W	24 24 48 48 48 48 48	HOUSE SIDE SHIELD
		* = Specify Voltage	68	7548	150W		
<u>15'0"- 4" Sq - 11Ga</u> 15'0"- 4" Sq - 11Ga	SNTS-154-11-2180/QSR/2480/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-154-11-2180/QSR/2480/PLED-IV/(X)/(CX)/RAL-8019/DBZ	□ 347 □ 480	68	7348	150W	24 24	
20'0"- 4" Sq - 7Ga 20'0"- 4" Sq - 7Ga 25'0"- 4" Sq - 7Ga 25'0"- 4" Sq - 7Ga	SNTS-204-7-2180/QSR/4850/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-204-7-2180/QSR/4850/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-III/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ SNTS-254-7-2180/QSR/4810/PLED-IV/(X)/(CX)/RAL-8019/DBZ		79 79 160 160	10349 10270 18240 18040	250W 250W 400W 400W	48 48 48 48	



U.S. ARCHITECTURAL